



**SPECIFICATIONS:**

- Concrete: 4000 psi @ 28 days
- Reinforcement: ASTM A615-Grade 60
- Entrained Air: 5-9%
- Fiber rein: Forta Ferro macrofiber

**GUARDIAN CONCRETE  
PRODUCTS INC.**  
2140 Maxon Rd.  
Schenectady, NY 12308  
Fax (518) 372-6729

**1000 GALLON  
SEAMLESS  
PUMP STATION TANK**

SCALE: NOT TO SCALE

DATE: MARCH 12, 2007

TELEPHONE NO.: (518) 372-0080

JOB: GENERAL CATALOG DRAWING